

STANDARD INSPECTION REPORT OF A GAS TRANSMISSION PIPELINE

A completed **Standard Inspection Report** is to be submitted to the Director within 60 days from completion of the inspection. A **Post Inspection Memorandum (PIM)** is to be completed and submitted to the Director within 30 days from the completion of the inspection, or series of inspections, and is to be filed as part of the **Standard Inspection Report**.

Inspection Report		Post Inspection Memorandum	
Inspector/Submit Date: _____		Inspector/Submit Date: _____	
		Peer Review/Date: _____	
		Director Approval/Date: _____	
POST INSPECTION MEMORANDUM (PIM)			
Name of Operator:		OPID #:	
Name of Unit(s):		Unit #(s):	
Records Location:			
Unit Type & Commodity:			
Inspection Type:		Inspection Date(s):	
PHMSA Representative(s):		AFO Days:	

Summary:

Findings:

STANDARD INSPECTION REPORT OF A GAS TRANSMISSION PIPELINE

Name of Operator:		
OP ID No. ⁽¹⁾		Unit ID No. ⁽¹⁾
HQ Address:	System/Unit Name & Address: ⁽¹⁾	
Co. Official: Phone No.: Fax No.: Emergency Phone No.:	Activity Record ID No.: Phone No.: Fax No.: Emergency Phone No.:	
Persons Interviewed	Title	Phone No.
PHMSA Representative(s) ⁽¹⁾		Inspection Date(s) ⁽¹⁾
Company System Maps (Copies for Region Files):		

Unit Description:

Portion of Unit Inspected: ⁽¹⁾
--

<p>For gas transmission pipeline inspections, the attached evaluation form should be used in conjunction with 49 CFR 191 and 192 during PHMSA inspections. Refer to the Hub Joint O&M team inspection schedule to identify inter-regional operators. For those operators, procedures do not have to be evaluated for content unless: 1) new or amended regulations have been placed in force after the team inspection, or 2) procedures have changed since the team inspection. Items in the procedures sections of this form identified with “*” reflect applicable and more restrictive new or amended regulations that became effective between 03/14/01 and 03/14/06.</p>
--

¹ Information not required if included on page 1.
Form I Standard Inspection Report of a Gas Transmission Pipeline (Rev. 03/17/06 through Amdt. 192-102)

STANDARD INSPECTION REPORT OF A GAS TRANSMISSION PIPELINE

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

49 CFR PART 191

	REPORTING PROCEDURES	S	U	N/A	N/C
.605(b)(4)	Procedures for gathering data for incident reporting				
	191.5 Telephonically reporting incidents to NRC (800) 424-8802				
	191.15(a) 30-day follow-up written report (Form 7100-2)				
	191.15(b) Supplemental report (to 30-day follow-up)				
.605(a)	191.23 Reporting safety-related condition (SRCR)				
	191.25 Filing the SRCR within 5 days of determination, but not later than 10 days after discovery				
	191.27 Offshore pipeline condition reports – filed within 60 days after the inspections				
.605(d)	Instructions to enable operation and maintenance personnel to recognize potential Safety Related Conditions				

Comments:

49 CFR PART 192

	CUSTOMER NOTIFICATION PROCEDURES	S	U	N/A	N/C
.13(c)	.16 Procedures for notifying new customers, within 90 days, of their responsibility for those selections of service lines not maintained by the operator.				

	NORMAL OPERATING and MAINTENANCE PROCEDURES	S	U	N/A	N/C
.605(a)	.605(a) O&M Plan review and update procedure (1 per year/15 months)				
	.605(b)(3) Making construction records, maps, and operating history available to appropriate operating personnel				
	.605(b)(5) Start up and shut down of the pipeline to assure operation within MAOP plus allowable buildup				
	.605(b)(8) Periodically reviewing the work done by operator's personnel to determine the effectiveness and adequacy of the procedures used in normal operation and maintenance and modifying the procedures when deficiencies are found				
	.605(b)(9) Taking adequate precautions in excavated trenches to protect personnel from the hazards of unsafe accumulations of vapors or gas, and making available when needed at the excavation, emergency rescue equipment, including a breathing apparatus and a rescue harness and line				
	.605(b)(10) Routine inspection and testing of pipe-type or bottle-type holders				
	* .605(b)(11) Responding promptly to a report of a gas odor inside or near a building, unless the operator's emergency proced. under §192.615(a)(3) specifically apply to these reports. Amdt 192-93 pub. 9/15/03, eff. 10/15/03.				

Comments:

STANDARD INSPECTION REPORT OF A GAS TRANSMISSION PIPELINE

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

.605(a)	ABNORMAL OPERATING PROCEDURES		S	U	N/A	N/C
	.605(c)(1)	Procedures for responding to, investigating, and correcting the cause of:				
		(i) Unintended closure of valves or shut downs				
		(ii) Increase or decrease in pressure or flow rate outside of normal operating limits				
		(iii) Loss of communications				
		(iv) The operation of any safety device				
		(v) Malfunction of a component, deviation from normal operations or personnel error				
	.605(c)(2)	Checking variations from normal operation after abnormal operations ended at sufficient critical locations				
	.605(c)(3)	Notifying the responsible operating personnel when notice of an abnormal operation is received				
	.605(c)(4)	Periodically reviewing the response of operating personnel to determine the effectiveness of the procedures and taking corrective action where deficiencies are found				

Comments:

.605(a)	CHANGE in CLASS LOCATION PROCEDURES		S	U	N/A	N/C
	.609	Class location study				
	.611	Confirmation or revision of MAOP				

Comments:

.613	CONTINUING SURVEILLANCE PROCEDURES		S	U	N/A	N/C
	.613(a)	Procedures for surveillance and required actions relating to change in class location, failures, leakage history, corrosion, substantial changes in CP requirements, and unusual operating and maintenance conditions				
	.613(b)	Procedures requiring MAOP to be reduced, or other actions to be taken, if a segment of pipeline is in unsatisfactory condition				

Comments:

.605(a)	DAMAGE PREVENTION PROGRAM PROCEDURES		S	U	N/A	N/C
	.614	Participation in a qualified one-call program, or if available, a company program that complies with the following:				
		(1) Identify persons who engage in excavating				
		(2) Provide notification to the public in the One Call area				
		(3) Provide means for receiving and recording notifications of pending excavations				
		(4) Provide notification of pending excavations to the members				

STANDARD INSPECTION REPORT OF A GAS TRANSMISSION PIPELINE

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

	DAMAGE PREVENTION PROGRAM PROCEDURES	S	U	N/A	N/C
	(5) Provide means of temporary marking for the pipeline in the vicinity of the excavations				
	(6) Provides for follow-up inspection of the pipeline where there is reason to believe the pipeline could be damaged				
	(i) Inspection must be done to verify integrity of the pipeline				
	(ii) After blasting, a leak survey must be conducted as part of the inspection by the operator				

Comments:

.615	EMERGENCY PROCEDURES	S	U	N/A	N/C
	.615(a)(1) Receiving, identifying, and classifying notices of events which require immediate response by the operator				
	.615(a)(2) Establish and maintain communication with appropriate public officials regarding possible emergency				
	.615(a)(3) Prompt response to each of the following emergencies:				
	(i) Gas detected inside a building				
	(ii) Fire located near a pipeline				
	(iii) Explosion near a pipeline				
	(iv) Natural disaster				
	.615(a)(4) Availability of personnel, equipment, instruments, tools, and material required at the scene of an emergency				
	.615(a)(5) Actions directed towards protecting people first, then property				
	.615(a)(6) Emergency shutdown or pressure reduction to minimize hazards to life or property				
	.615(a)(7) Making safe any actual or potential hazard to life or property				
	.615(a)(8) Notifying appropriate public officials required at the emergency scene and coordinating planned and actual responses with these officials				
	.615(a)(9) Instructions for restoring service outages after the emergency has been rendered safe				
	.615(a)(10) Investigating accidents and failures as soon as possible after the emergency				
	.615(b)(1) Furnishing applicable portions of the emergency plan to supervisory personnel who are responsible for emergency action				
	.615(b)(2) Training appropriate employees as to the requirements of the emergency plan and verifying effectiveness of training				
	.615(b)(3) Reviewing activities following emergencies to determine if the procedures were effective				
	.615(c) Establish and maintain liaison with appropriate public officials, such that both the operator and public officials are aware of each other's resources and capabilities in dealing with gas emergencies				

Comments:

STANDARD INSPECTION REPORT OF A GAS TRANSMISSION PIPELINE

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

.605(a)	PUBLIC EDUCATION PROCEDURES		S	U	N/A	N/C
	.616	Establishing a continuing educational program (in English and other pertinent languages) to better inform the public in how to recognize and report potential gas pipeline emergencies [prior to June 20, 2006]				
*	.616	Public Awareness Program in accordance with API RP 1162 [HQ clearinghouse review after June 20, 2006] Amdt 192-99 pub. 5/19/05, eff. 06/20/05.				

Comments:

.617	FAILURE INVESTIGATION PROCEDURES		S	U	N/A	N/C
	.617	Analyzing accidents and failures including laboratory analysis where appropriate to determine cause and prevention of recurrence				

Comments:

.605(a)	MAOP PROCEDURES			S	U	N/A	N/C															
	.619	Establishing MAOP so that it is commensurate with the class location																				
	MAOP cannot exceed the lowest of the following:																					
	(a)(1) Design pressure of the weakest element																					
	(a)(2) Test pressure divided by applicable factor																					
	*	(a)(3) The highest actual operating pressure to which the segment of line was subjected during the 5 years preceding the applicable date in second column, unless the segment was tested according to .619(a)(2) after the applicable date in the third column or the segment was uprated according to subpart K. Amdt 192-102 pub. 3/15/06, eff. 04/14/06. For gathering line related compliance deadlines and additional gathering line requirements, refer to Part 192 including this amendment.																				
	<table><tr><th>Pipeline segment</th><th>Pressure date</th><th>Test date</th></tr><tr><td>--Onshore gathering line that first became subject to this part (other than § 192.612) after April 13, 2006.</td><td>March 15, 2006, or date line becomes subject to this part, whichever is later.</td><td>5 years preceding applicable date in second column.</td></tr><tr><td>-- Onshore transmission line that was a gathering line not subject to this part before March 15, 2006.</td><td></td><td></td></tr><tr><td>Offshore gathering lines.</td><td>July 1, 1976.</td><td>July 1, 1971.</td></tr><tr><td>All other pipelines.</td><td>July 1, 1970.</td><td>July 1, 1965.</td></tr></table>			Pipeline segment	Pressure date	Test date	--Onshore gathering line that first became subject to this part (other than § 192.612) after April 13, 2006.	March 15, 2006, or date line becomes subject to this part, whichever is later.	5 years preceding applicable date in second column.	-- Onshore transmission line that was a gathering line not subject to this part before March 15, 2006.			Offshore gathering lines.	July 1, 1976.	July 1, 1971.	All other pipelines.	July 1, 1970.	July 1, 1965.				
	Pipeline segment	Pressure date	Test date																			
	--Onshore gathering line that first became subject to this part (other than § 192.612) after April 13, 2006.	March 15, 2006, or date line becomes subject to this part, whichever is later.	5 years preceding applicable date in second column.																			
	-- Onshore transmission line that was a gathering line not subject to this part before March 15, 2006.																					
Offshore gathering lines.	July 1, 1976.	July 1, 1971.																				
All other pipelines.	July 1, 1970.	July 1, 1965.																				
(a)(4) Maximum safe pressure determined by operator.																						
(b) Overpressure protective devices must be installed if .619(a)(4) is applicable																						

STANDARD INSPECTION REPORT OF A GAS TRANSMISSION PIPELINE

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

	MAOP PROCEDURES	S	U	N/A	N/C
*	(c) The requirements on pressure restrictions in this section do not apply in the following instance. An operator may operate a segment of pipeline found to be in satisfactory condition, considering its operating and maintenance history, at the highest actual operating pressure to which the segment was subjected during the 5 years preceding the applicable date in the second column of the table in paragraph (a)(3) of this section. An operator must still comply with § 192.611. Amdt 192-102 pub. 3/15/06, eff. 04/14/06. For gathering line related compliance deadlines and additional gathering line requirements, refer to Part 192 including this amendment.				

Comments:

.13(c)	PRESSURE TEST PROCEDURES	S	U	N/A	N/C
	.503 Pressure testing				

Comments:

.13(c)	UPRATING PROCEDURES	S	U	N/A	N/C
	.553 Uprating				

Comments:

.605(a)	ODORIZATION of GAS PROCEDURES	S	U	N/A	N/C
	.625(b) Odorized gas in Class 3 or 4 locations (if applicable) – must be readily detectable by person with normal sense of smell at $\frac{1}{5}$ of the LEL				
*	.625(f) Periodic gas sampling, using an instrument capable of determining the percentage of gas in air at which the odor becomes readily detectable. Amdt 192-93 pub.9/15/03, eff. 10/15/03.				

Comments:

.605(a)	TAPPING PIPELINES UNDER PRESSURE PROCEDURES	S	U	N/A	N/C
	.627 Hot taps must be made by a qualified crew NDT testing is suggested prior to tapping the pipe. Reference API RP 2201 for Best Practices .				

.605(a)	PIPELINE PURGING PROCEDURES	S	U	N/A	N/C
---------	-----------------------------	---	---	-----	-----

STANDARD INSPECTION REPORT OF A GAS TRANSMISSION PIPELINE

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

	PIPELINE PURGING PROCEDURES	S	U	N/A	N/C
.629	Purging of pipelines must be done to prevent entrapment of an explosive mixture in the pipeline				
	(a) Lines containing air must be properly purged.				
	(b) Lines containing gas must be properly purged				

Comments:

.605(a)	MAINTENANCE PROCEDURES	S	U	N/A	N/C
.703(b)	Each segment of pipeline that becomes unsafe must be replaced, repaired, or removed from service				
	(c) Hazardous leaks must be repaired promptly				

Comments:

.605(b)	TRANSMISSION LINES - PATROLLING & LEAKAGE SURVEY PROCEDURES			S	U	N/A	N/C												
	.705(a)	Patrolling ROW conditions																	
	(b)	Maximum interval between patrols of lines:																	
	<table><tr><td>Class Location</td><td>At Highway and Railroad Crossings</td><td>At All Other Places</td></tr><tr><td>1 and 2</td><td>2/yr (7½ months)</td><td>1/yr (15 months)</td></tr><tr><td>3</td><td>4/yr (4½ months)</td><td>2/yr (7½ months)</td></tr><tr><td>4</td><td>4/yr (4½ months)</td><td>4/yr (4½ months)</td></tr></table>			Class Location	At Highway and Railroad Crossings	At All Other Places	1 and 2	2/yr (7½ months)	1/yr (15 months)	3	4/yr (4½ months)	2/yr (7½ months)	4	4/yr (4½ months)	4/yr (4½ months)				
	Class Location	At Highway and Railroad Crossings	At All Other Places																
	1 and 2	2/yr (7½ months)	1/yr (15 months)																
	3	4/yr (4½ months)	2/yr (7½ months)																
	4	4/yr (4½ months)	4/yr (4½ months)																
	.706	Leakage surveys – 1 year/15 months																	
	Leak detector equipment survey requirements for lines transporting un-odorized gas																		
(a) Class 3 locations - 7½ months but at least twice each calendar year																			
(b) Class 4 locations - 4½ months but at least 4 times each calendar year																			

Comments:

.605(b)	LINE MARKER PROCEDURES	S	U	N/A	N/C
.707	Line markers installed and labeled as required				

STANDARD INSPECTION REPORT OF A GAS TRANSMISSION PIPELINE

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

Comments:

.605(b)	RECORD KEEPING PROCEDURES	S	U	N/A	N/C
	.709 Records must be maintained...				
	(a) Repairs to the pipe – life of system				
	(b) Repairs to “other than pipe” – 5 years				
	(c) Operation (Sub L) and Maintenance (Sub M) patrols, surveys, tests – 5 years or until next one				

Comments:

.605(b)	FIELD REPAIR PROCEDURES	S	U	N/A	N/C
	Imperfections and Damages				
	.713(a) Repairs of imperfections and damages on pipelines operating above 40% SMYS				
	(1) Cut out a cylindrical piece of pipe and replace with pipe of \geq design strength				
	(2) Use of a reliable engineering method				
	.713(b) Reduce operating pressure to a safe level during the repair				
	Permanent Field Repair of Welds				
	.715 Welds found to be unacceptable under §192.241(c) must be repaired by:				
	(a) If feasible, taking the line out of service and repairing the weld in accordance with the applicable requirements of §192.245 .				
	(b) If the line remains in service, the weld may be repaired in accordance with §192.245 if:				
	(1) The weld is not leaking				
	(2) The pressure is reduced to produce a stress that is 20% of SMYS or less				
	(3) Grinding is limited so that 1/8 inch of pipe weld remains				
	(c) If the weld cannot be repaired in accordance with (a) or (b) above, a full encirclement welded split sleeve must be installed				
	Permanent Field Repairs of Leaks				
	.717 Field repairs of leaks must be made as follows:				
	(a) Replace by cutting out a cylinder and replace with pipe similar or of greater design				
	(b)(1) Install a full encirclement welded split sleeve of an appropriate design unless the pipe is joined by mechanical couplings and operates at less than 40% SMYS				
	(b)(2) A leak due to a corrosion pit may be repaired by installing a bolt on leak clamp				
	(b)(3) For a corrosion pit leak, if a pipe is not more than 40,000 psi SMYS , the pits may be repaired by fillet welding a steel plate . The plate must have rounded corners and the same thickness or greater than the pipe, and not more than 1/2D of the pipe size				
	(b)(4) Submerged offshore pipe or pipe in inland navigable waterways may be repaired with a mechanically applied full encirclement split sleeve of appropriate design				
	(b)(5) Apply reliable engineering method				
	Testing of Repairs				
	.719(a) Replacement pipe must be pressure tested to meet the requirements of a new pipeline				
	(b) For lines of 6-inch diameter or larger and that operate at 20% of more of SMYS , the repair must be nondestructively tested in accordance with §192.241(c)				

STANDARD INSPECTION REPORT OF A GAS TRANSMISSION PIPELINE

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

Comments:

.605(b)	ABANDONMENT or DEACTIVATION of FACILITIES PROCEDURES	S	U	N/A	N/C
	.727(b) Operator must disconnect both ends, purge, and seal each end before abandonment or a period of deactivation where the pipeline is not being maintained. Offshore abandoned pipelines must be filled with water or an inert material, with the ends sealed				
	(c) Except for service lines, each inactive pipeline that is not being maintained under Part 192 must be disconnected from all gas sources/supplies, purged, and sealed at each end.				
	(d) Whenever service to a customer is discontinued, do the procedures indicate one of the following:				
	(1) The valve that is closed to prevent the flow of gas to the customer must be provided with a locking device or other means designed to prevent the opening of the valve by persons other than those authorized by the operator				
	(2) A mechanical device or fitting that will prevent the flow of gas must be installed in the service line or in the meter assembly				
	(3) The customer's piping must be physically disconnected from the gas supply and the open pipe ends sealed				
	(e) If air is used for purging, the operator shall ensure that a combustible mixture is not present after purging				
	.727 (g) Operator must file reports upon abandoning underwater facilities crossing navigable waterways, including offshore facilities.				

Comments:

.605(b)	COMPRESSOR STATION PROCEDURES	S	U	N/A	N/C
	.605(b)(6) Maintenance procedures, including provisions for isolating units or sections of pipe and for purging before returning to service				
	.605(b)(7) Starting, operating, and shutdown procedures for gas compressor units				
	.731 Inspection and testing procedures for remote control shutdowns and pressure relieving devices (1 per yr/15 months), prompt repair or replacement				
	.735 (a) Storage of excess flammable or combustible materials at a safe distance from the compressor buildings				
	(b) Tank must be protected according to NFPA #30				
	.736 Compressor buildings in a compressor station must have fixed gas detection and alarm systems (must be performance tested), unless:				
	§ 50% of the upright side areas are permanently open, or				
	§ It is an unattended field compressor station of 1000 hp or less				

Comments:

STANDARD INSPECTION REPORT OF A GAS TRANSMISSION PIPELINE

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

Comments:

.605(b)	PRESSURE LIMITING and REGULATING STATION PROCEDURES		S	U	N/A	N/C						
	.739(a)	Inspection and testing procedures for pressure limiting stations, relief devices, pressure regulating stations and equipment (1 per yr/15 months)										
		(1) In good mechanical condition										
		(2) Adequate from the standpoint of capacity and reliability of operation for the service in which it is employed										
*	.739(a)	(3) Set to control or relieve at correct pressures consistent with .201(a), except for .739(b). Amdt. 192-96 pub. 5/17/04, eff.10/8/04										
		(4) Properly installed and protected from dirt, liquids, other conditions that may prevent proper oper.										
*	.739(b)	For steel lines if MAOP is determined per .619(c) and the MAOP is 60 psi (414 kPa) gage or more . . . Amdt. 192-96 pub. 5/17/04, eff.10/8/04										
		<table><tr><td>If MAOP produces hoop stress that</td><td>Then the pressure limit is:</td></tr><tr><td>Is greater than 72 percent of SMYS</td><td>MAOP plus 4 percent</td></tr><tr><td>Is unknown as a percent of SMYS</td><td>A pressure that will prevent unsafe operation of the pipeline considering its operating and maintenance history and MAOP</td></tr></table>	If MAOP produces hoop stress that	Then the pressure limit is:	Is greater than 72 percent of SMYS	MAOP plus 4 percent	Is unknown as a percent of SMYS	A pressure that will prevent unsafe operation of the pipeline considering its operating and maintenance history and MAOP				
If MAOP produces hoop stress that	Then the pressure limit is:											
Is greater than 72 percent of SMYS	MAOP plus 4 percent											
Is unknown as a percent of SMYS	A pressure that will prevent unsafe operation of the pipeline considering its operating and maintenance history and MAOP											
	.743	Testing of Relief Devices										
*	.743	(a) Capacity must be consistent with .201(a) except for .739(b), and be determined 1 per yr/15 mo. Amdt. 192-96 pub. 5/17/04, eff.10/8/04										
*	.743	(b) If calculated, capacities must be compared; annual review and documentation are required. Amdt. 192-93 pub. 9/15/03, eff. 10/15/03.										
*	.743	(c) If insufficient capacity, new or additional devices must be installed to provide required capacity. Amdt. 192-93 pub. 9/15/03, eff. 10/15/03.										

Comments:

.605(b)	VALVE AND VAULT MAINTENANCE PROCEDURES		S	U	N/A	N/C
		Valves				
	.745	(a) Inspect and partially operate each transmission valve that might be required during an emergency (1 per yr/15 months)				
*	.745	(b) Prompt remedial action required, or designate alternative valve. Amdt. 192-93 pub. 9/15/03, eff. 10/15/03.				
		Vaults				
	.749	Inspection of vaults greater than 200 cubic feet (1 per yr/15 months)				

.605(b)	PREVENTION of ACCIDENTAL IGNITION PROCEDURES		S	U	N/A	N/C
	.751	Reduce the hazard of fire or explosion by:				
		(a) Removal of ignition sources in presence of gas and providing for a fire extinguisher				
		(b) Prevent welding or cutting on a pipeline containing a combustible mixture				
		(c) Post warning signs				

STANDARD INSPECTION REPORT OF A GAS TRANSMISSION PIPELINE

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

Comments:

.13(c)		WELDING AND WELD DEFECT REPAIR/REMOVAL PROCEDURES	S	U	N/A	N/C
*	.225	(a) Welding procedures must be qualified under Section 5 of API 1104 (19 th ed.1999, 10/31/01 errata) or Section IX of ASME Boiler and Pressure Code (2001 ed.) by destructive test. Amdt.192-94 pub. 6/14/04, eff. 7/14/04				
		(b) Retention of welding procedure – details and test				
*	.227	(a) Welders must be qualified by Section 6 of API 1104 (19 th ed.1999, 10/31/01 errata) or Section IX of ASME Boiler and Pressure Code (2001 ed.) See exception in .227(b). Amdt.192-94 pub. 6/14/04, eff. 7/14/04				
		(b) Welders may be qualified under section I of Appendix C to weld on lines that operate at < 20% SMYS .				
	.229	(a) To weld on compressor station piping and components, a welder must successfully complete a destructive test				
		(b) Welder must have used welding process within the preceding 6 months				
		(c) A welder qualified under .227(a)–				
*	.229(c)	(1) May not weld on pipe that operates at \geq 20% SMYS unless within the preceding 6 calendar months the welder has had one weld tested and found acceptable under the sections 6 or 9 of API Standard 1104 ; may maintain an ongoing qualification status by performing welds tested and found acceptable at least twice per year , not exceeding 7½ months ; may not requalify under an earlier referenced edition. Amdt.192-94 pub. 6/14/04, eff. 7/14/04.				
		(2) May not weld on pipe that operates at < 20% SMYS unless is tested in accordance with .229(c)(1) or requalifies under .229(d)(1) or (d)(2).				
		(d) Welders qualified under .227(b) may not weld unless:				
		(1) Requalified within 1 year/15 months , or				
		(2) Within 7½ months but at least twice per year had a production weld pass a qualifying test				
	.231	Welding operation must be protected from weather				
	.233	Miter joints (consider pipe alignment)				
	.235	Welding preparation and joint alignment				
*	.241	(a) Visual inspection must be conducted by an individual qualified by appropriate training and experience to ensure: Amdt.192-94 pub. 6/14/04, eff. 7/14/04				
		(1) Compliance with the welding procedure				
		(2) Weld is acceptable in accordance with Section 9 of API 1104				
		(b) Welds on pipelines to be operated at 20% or more of SMYS must be nondestructively tested in accordance with 192.243 except welds that are visually inspected and approved by a qualified welding inspector if:				
		(1) The nominal pipe diameter is less than 6 inches , or				
		(2) The pipeline is to operate at a pressure that produces a hoop stress of less than 40% of SMYS and the welds are so limited in number that nondestructive testing is impractical				
*	.241	(c) Acceptability based on visual inspection or NDT is determined according to Section 9 of API 1104 . If a girth weld is unacceptable under Section 9 for a reason other than a crack, and if Appendix A to API 1104 applies to the weld, the acceptability of the weld may be further determined under that appendix. Amdt.192-94 pub. 6/14/04, eff. 7/14/04				
	.245	Repair and Removal of Weld Defects				
		(a) Each weld that is unacceptable must be removed or repaired. Except for offshore pipelines, a weld must be removed if it has a crack that is more than 8% of the weld length				

STANDARD INSPECTION REPORT OF A GAS TRANSMISSION PIPELINE

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

.13(c)	WELDING AND WELD DEFECT REPAIR/REMOVAL PROCEDURES	S	U	N/A	N/C
	(b) Each weld that is repaired must have the defect removed down to sound metal, and the segment to be repaired must be preheated if conditions exist which would adversely affect the quality of the weld repair. After repair, the weld must be inspected and found acceptable.				
	(c) Repair of a crack or any other defect in a previously repaired area must be in accordance with a written weld repair procedure, qualified under §192.225				
	§ Sleeve Repair – low hydrogen rod (Best Practices –ref. API 1104 App. B, In Service Welding)				

Comments:

.13(c)	NONDESTRUCTIVE TESTING PROCEDURES	S	U	N/A	N/C
.243	(a) Nondestructive testing of welds must be performed by any process, other than trepanning, that clearly indicates defects that may affect the integrity of the weld				
	(b) Nondestructive testing of welds must be performed:				
	(1) In accordance with a written procedure, and				
	(2) By persons trained and qualified in the established procedures and with the test equipment used				
	(c) Procedures established for proper interpretation of each nondestructive test of a weld to ensure acceptability of the weld under 192.241(c)				
	(d) When nondestructive testing is required under §192.241(b), the following percentage of each day's field butt welds, selected at random by the operator, must be nondestructively tested over the entire circumference				
	(1) In Class 1 locations at least 10%				
	(2) In Class 2 locations at least 15%				
	(3) In Class 3 and 4 locations, at crossings of a major navigable river, offshore, and within railroad or public highway rights-of-way, including tunnels, bridges, and overhead road crossings, 100% unless impractical, then 90%. Nondestructive testing must be impractical for each girth weld not tested.				
	(4) At pipeline tie-ins, 100%				
	(e) Except for a welder whose work is isolated from the principal welding activity, a sample of each welder's work for each day must be nondestructively tested, when nondestructive testing is required under §192.241(b)				
	(f) Nondestructive testing – the operator must retain, for the life of the pipeline, a record showing by mile post, engineering station, or by geographic feature, the number of welds nondestructively tested, the number of welds rejected, and the disposition of the rejected welds.				

Comments:

.273(b)	JOINING of PIPELINE MATERIALS	S	U	N/A	N/C
.281	Joining of plastic pipe				
	§ Type of plastic used				
	§ Proper markings in accordance with §192.63				
	§ Manufacturer				

STANDARD INSPECTION REPORT OF A GAS TRANSMISSION PIPELINE

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

JOINING of PIPELINE MATERIALS			S	U	N/A	N/C
	\$	Type of joint used				
*	.283	Qualified joining procedures for plastic pipe must be in place Amdt.192-94 pub. 6/14/04, eff. 7/14/04				
*	.285	Persons making joints with plastic pipe must be qualified Amdt.192-94 pub. 6/14/04, eff. 7/14/04				
*	.287	Persons inspecting plastic joints must be qualified Amdt.192-94 pub. 6/14/04, eff. 7/14/04				

Comments:

CORROSION CONTROL PROCEDURES			S	U	N/A	N/C
.605(b)	.453	Are corrosion procedures established for:				
	\$	Design				
	\$	Operations				
	\$	Installation				
	\$	Maintenance				
	.455	(a) For pipelines installed after July 31, 1971 , buried segments must be externally coated and				
		(b) cathodically protected within one year after construction (see exceptions in code)				
		(c) Aluminum may not be installed in a buried or submerged pipeline if exposed to an environment with a natural pH in excess of 8 (see exceptions in code)				
	.457	(a) All effectively coated steel transmission pipelines installed prior to August 1, 1971 , must be cathodically protected				
		(b) If installed before August 1, 1971 , cathodic protection must be provided in areas of active corrosion for: bare or ineffectively coated transmission lines, and bare or coated c/s, regulator sta, and meter sta. piping.				
	.459	Examination of buried pipeline when exposed: if corrosion is found, further investigation is required				
	.461	Procedures must address the protective coating requirements of the regulations. External coating on the steel pipe must meet the requirements of this part.				
	.463	Cathodic protection level according to Appendix D criteria				
	.465	(a) Pipe-to-soil monitoring (1 per yr/15 months)				
		(b) Rectifier monitoring (6 per yr/2½ months)				
		(c) Interference bond monitoring (as required)				
		(d) Prompt remedial action to correct any deficiencies indicated by the monitoring				
	* .465	(e) Electrical surveys (closely spaced pipe to soil) on bare/unprotected lines, cathodically protect active corrosion areas (1 per 3 years/39 months) Amdt 192-93 pub.9/15/03, eff. 10/15/03.				
	.467	Electrical isolation (include casings)				
	.469	Sufficient test stations to determine CP adequacy				
	.471	Test lead maintenance				
	.473	Interference currents				
	.475	(a) Proper procedures for transporting corrosive gas?				
		(b) Removed pipe must be inspected for internal corrosion. If found, the adjacent pipe must be inspected to determine extent. Certain pipe must be replaced. Steps must be taken to minimize internal corrosion.				
	.477	Internal corrosion control coupon (or other suit. Means) monitoring (2 per yr/7½ months)				
	.479	(a) Each exposed pipe must be cleaned and coated (see exceptions under .479(c))				
		Offshore splash zones and soil-to-air interfaces must be coated				

STANDARD INSPECTION REPORT OF A GAS TRANSMISSION PIPELINE

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

CORROSION CONTROL PROCEDURES		S	U	N/A	N/C
	(b) Coating material must be suitable				
	Coating is not required where operator has proven that corrosion will:				
	(c) (1) Only be a light surface oxide, or				
	(2) Not affect safe operation before next scheduled inspection				
* .481	(a) Atmospheric corrosion control monitoring (1 per 3 yrs/39 months onshore; 1 per yr/15 months offshore)				
* .481	(b) Special attention required at soil/air interfaces, thermal insulation, under disbonded coating, pipe supports, splash zones, deck penetrations, spans over water Amdt 192-93 pub.9/15/03, eff. 10/15/03.				
* .481	(c) Protection must be provided if atmospheric corrosion is found (per §192.479) Amdt 192-93 pub.9/15/03, eff. 10/15/03.				
.483	Replacement and required pipe must be coated and cathodically protected (see code for exceptions)				
.485	(a) Procedures to replace pipe or reduce the MAOP if general corrosion has reduced the wall thickness?				
	(b) Procedures to replace/repair pipe or reduce MAOP if localized corrosion has reduced wall thickness (unless reliable engineering repair method exists)?				
	(c) Procedures to use Rstreng or B-31G to determine remaining wall strength?				
.491	Corrosion control maps and record retention (pipeline service life or 5 yrs)				

Comments:

UNDERWATER INSPECTION PROCEDURES – GULF of MEXICO and INLETS		S	U	N/A	N/C
* .612(a)	Operator must have a procedure prepared by August 10, 2005 to identify pipelines in the Gulf of Mexico and its inlets in waters less than 15 feet (4.6 meters) deep that are at risk of being an exposed underwater pipeline or a hazard to navigation? Amdt. 192-98 pub. 8/10/04, eff. 9/9/04				
* .612(b)	Operator must conduct appropriate periodic underwater inspections based on the identified risk Amdt. 192-98 pub.8/10/04, eff. 9/9/04				
.612(c)	Do procedures require the operator to take action when the operator discovers that a pipeline is exposed on the seabed, or constitutes a hazard to navigation:				
	(1) Promptly, within 24 hours , notify the National Response Center of the location of the pipeline?				
	(2) Promptly, but not later than 7 days after discovery, mark the location of the pipeline in accordance with 33 CFR Part 64 at the ends of the pipeline segment and at intervals of not over 500 yards long , except that a pipeline segment less than 200 yards long need only be marked at the center?				
	(3) Place the pipeline so that the top of the pipe is 36 inches below the seabed for normal excavation or 18 inches for rock excavation within 6 months of discovery or not later than November 1 of the following year if the 6 month period is later than November 1 of the year the discovery is made? See code re: engineering alternatives, PHMSA notification.				

Subpart N — Qualification of Pipeline Personnel Procedures		S	U	N/A	N/C
.801-.809	Refer to Operator Qualification Inspection Forms and Protocols (OPS web site)				

Subpart O — Pipeline Integrity Management		S	U	N/A	N/C
.901-.951	This form does not cover Gas Pipeline Integrity Management Programs				

Comments:

STANDARD INSPECTION REPORT OF A GAS TRANSMISSION PIPELINE

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

Comments:

PIPELINE INSPECTION (Field)		S	U	N/A	N/C
.179	Valve Protection from Tampering or Damage				
.463	Cathodic Protection				
.465	Rectifiers				
.479	Pipeline Components Exposed to the Atmosphere				
.605	Knowledge of Operating Personnel				
.612 (c) (2)	Pipelines exposed on seabed (Gulf of Mexico and Inlets): Marking				
.707	ROW Markers, Road and Railroad Crossings				
.719	Pre-pressure Tested Pipe (Markings and Inventory)				
.739	Pressure Limiting and Regulating Devices (Mechanical)				
.743	Pressure Limiting and Regulating Devices (Capacities)				
.745	Valve Maintenance				
.751	Warning Signs				
.801 - .809	Operator Qualification - Use PHMSA Form 15 Operator Qualification Field Inspection Protocol Form				

Comments:

COMPRESSOR STATIONS INSPECTION (Field)		S	U	N/A	N/C
(Note: Facilities may be "Grandfathered")					
.163 (c)	Main operating floor must have (at least) two (2) separate and unobstructed exits				
	Door latch must open from inside without a key				
	Doors must swing outward				
(d)	Each fence around a compressor station must have (at least) 2 gates or other facilities for emergency exit				
	Each gate located within 200 ft of any compressor plant building must open outward				
	When occupied, the door must be opened from the inside without a key				
(e)	Does the equipment and wiring within compressor stations conform to the National Electric Code, ANSI/NFPA 70?				
.165(a)	If applicable, are there liquid separator(s) on the intake to the compressors?				
.165(b)	Do the liquid separators have a manual means of removing liquids?				
	If slugs of liquid could be carried into the compressors, are there automatic dumps on the separators, Automatic compressor shutdown devices, or high liquid level alarms?				
.167(a)	ESD system must:				
	- Discharge blowdown gas to a safe location				
	- Block and blowdown the gas in the station				
	- Shut down gas compressing equipment, gas fires, electrical facilities in compressor building and near gas headers				
	- Maintain necessary electrical circuits for emergency lighting and circuits needed to protect equipment from damage				

STANDARD INSPECTION REPORT OF A GAS TRANSMISSION PIPELINE

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

COMPRESSOR STATIONS INSPECTION (Field)		S	U	N/A	N/C
(Note: Facilities may be “Grandfathered”)					
	ESD system must be operable from at least two locations, each of which is:				
.167 (b)	- Outside the gas area of the station				
	- Not more than 500 feet from the limits of the station				
	- ESD switches near emergency exits?				
	For stations supplying gas directly to distribution systems, is the ESD system configured so that the LDC will not be shut down if the ESD is activated?				
.167(c)	Are ESDs on platforms designed to actuate automatically by...				
	- For unattended compressor stations, when:				
	▪ The gas pressure equals MAOP plus 15%?				
	▪ An uncontrolled fire occurs on the platform?				
	- For compressor station in a building, when				
	▪ An uncontrolled fire occurs in the building?				
	▪ Gas in air reaches 50% or more of LEL in a building with a source of ignition (facility conforming to NEC Class 1, Group D is not a source of ignition)?				
.171(a)	Does the compressor station have adequate fire protection facilities? If fire pumps are used, they must not be affected by the ESD system.				
(b)	Do the compressor station prime movers (other than electrical movers) have over-speed shutdown?				
(c)	Do the compressor units alarm or shutdown in the event of inadequate cooling or lubrication of the unit(s)?				
(d)	Are the gas compressor units equipped to automatically stop fuel flow and vent the engine if the engine is stopped for any reason?				
(e)	Are the mufflers equipped with vents to vent any trapped gas?				
.173	Is each compressor station building adequately ventilated?				
.457	Is all buried piping cathodically protected?				
.481	Atmospheric corrosion of aboveground facilities				
.603	Does the operator have procedures for the start-up and shut-down of the station and/or compressor units?				
	Are facility maps current/up-to-date?				
.615	Emergency Plan for the station on site?				
.619	Review pressure recording charts and/or SCADA				
.707	Markers				
.731	Overpressure protection – reliefs or shutdowns				
.735	Are combustible materials in quantities exceeding normal daily usage, stored a safe distance from the compressor building?				
	Are aboveground oil or gasoline storage tanks protected in accordance with NFPA standard No. 30?				
.736	Gas detection – location				

Comments:					

CONVERSION TO SERVICE RECORDS		S	U	N/A	N/C
.14 (a)(2)	Visual inspection of right of way, aboveground and selected underground segments				
(a)(3)	Correction of unsafe defects and conditions				

STANDARD INSPECTION REPORT OF A GAS TRANSMISSION PIPELINE

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

CONVERSION TO SERVICE RECORDS		S	U	N/A	N/C
(a)(4)	Pipeline testing in accordance with Subpart J				
(b)	Pipeline records: investigations, tests, repairs, replacements, alterations (life of pipeline)				

REPORTING RECORDS		S	U	N/A	N/C
191.5	Telephonic reports to NRC (800-424-8802)				
191.15	Written incident reports; supplemental incident reports (DOT Form RSPA F 7100.2)				
191.17 (a)	Annual Report (DOT Form RSPA F 7100.2-1)				
191.23	Safety related condition reports				
191.27	Offshore pipeline condition reports				
192.727 (g)	Abandoned facilities offshore, onshore crossing commercially navigable waterways reports				

CONSTRUCTION RECORDS		S	U	N/A	N/C
.225	Test Results to Qualify Welding Procedures				
.227	Welder Qualification				
.241 (a)	Visual Weld Inspector Training/Experience				
.243 (b)(2)	Nondestructive Technician Qualification				
(c)	NDT procedures				
(f)	Total Number of Girth Welds				
(f)	Number of Welds Inspected by NDT				
(f)	Number of Welds Rejected				
(f)	Disposition of each Weld Rejected				
.303	Construction Specifications				
.325	Underground Clearance				
.327	Amount, Location, Cover of each Size of Pipe Installed				
.455	Cathodic Protection				

OPERATIONS and MAINTENANCE RECORDS		S	U	N/A	N/C
.16	Customer Notification (Verification – 90 days – and Elements)				
.603(b)	.605(a) Procedural Manual Review – Operations and Maintenance (1 per yr/15 months)				
.603(b)	.605(c) Abnormal Operations				
.603(b)	.605(b)(3) Availability of construction records, maps, operating history to operating personnel				
.603(b)	.605(b)(8) Periodic review of personnel work – effectiveness of normal O&M procedures				
.603(b)	.605(c)(4) Periodic review of personnel work – effectiveness of abnormal operation procedures				
.603(b)	.612(b) Gulf of Mexico/inlets: Periodic underwater inspections based on the identified risk				
.709	.614 Damage Prevention (Miscellaneous)				
.709	.609 Class Location Study (If Applicable)				
.603(b)	.615(b)(1) Location Specific Emergency Plan				
.603(b)	.615(b)(2) Emergency Procedure training, verify effectiveness of training				
.603(b)	.615(b)(3) Employee Emergency activity review, determine if procedures were followed.				
.603(b)	.615(c) Liaison Program with Public Officials				
.603(b)	.616 Public Education/Awareness Program				
.517	Pressure Testing				
.553(b)	Upgrading				
.709	.619 Maximum Allowable Operating Pressure (MAOP)				

STANDARD INSPECTION REPORT OF A GAS TRANSMISSION PIPELINE

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

OPERATIONS and MAINTENANCE RECORDS			S	U	N/A	N/C												
.709	.625	Odorization of Gas																
.709	.705	Patrolling (Refer to Table Below)																
<table border="1" style="width: 100%; border-collapse: collapse; margin: 5px;"> <thead> <tr> <th style="width: 30%;">Class Location</th> <th style="width: 35%;">At Highway and Railroad Crossings</th> <th style="width: 35%;">At All Other Places</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">1 and 2</td> <td style="text-align: center;">2/yr (7½ months)</td> <td style="text-align: center;">1/yr (15 months)</td> </tr> <tr> <td style="text-align: center;">3</td> <td style="text-align: center;">4/yr (4½ months)</td> <td style="text-align: center;">2/yr (7½ months)</td> </tr> <tr> <td style="text-align: center;">4</td> <td style="text-align: center;">4/yr (4½ months)</td> <td style="text-align: center;">4/yr (4½ months)</td> </tr> </tbody> </table>							Class Location	At Highway and Railroad Crossings	At All Other Places	1 and 2	2/yr (7½ months)	1/yr (15 months)	3	4/yr (4½ months)	2/yr (7½ months)	4	4/yr (4½ months)	4/yr (4½ months)
Class Location	At Highway and Railroad Crossings	At All Other Places																
1 and 2	2/yr (7½ months)	1/yr (15 months)																
3	4/yr (4½ months)	2/yr (7½ months)																
4	4/yr (4½ months)	4/yr (4½ months)																
.709	.706	Leak Surveys (Refer to Table Below)																
<table border="1" style="width: 100%; border-collapse: collapse; margin: 5px;"> <thead> <tr> <th style="width: 30%;">Class Location</th> <th style="width: 35%;">Required</th> <th style="width: 35%;">Not Exceed</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">1 and 2</td> <td style="text-align: center;">1/yr</td> <td style="text-align: center;">15 months</td> </tr> <tr> <td style="text-align: center;">3</td> <td style="text-align: center;">2/yr</td> <td style="text-align: center;">7½ months</td> </tr> <tr> <td style="text-align: center;">4</td> <td style="text-align: center;">4/yr</td> <td style="text-align: center;">4½ months</td> </tr> </tbody> </table>							Class Location	Required	Not Exceed	1 and 2	1/yr	15 months	3	2/yr	7½ months	4	4/yr	4½ months
Class Location	Required	Not Exceed																
1 and 2	1/yr	15 months																
3	2/yr	7½ months																
4	4/yr	4½ months																
.709	.731(a)	Compressor Station Relief Devices (1 per yr/15 months)																
.709	.731(c)	Compressor Station Emergency Shutdown (1 per yr/15 months)																
.709	.736(c)	Compressor Stations – Detection and Alarms (Performance Test)																
.709	.739	Pressure Limiting and Regulating Stations (1 per yr/15 months)																
.709	.743	Pressure Limiting and Regulator Stations – Capacity (1 per yr/15 months)																
.709	.745	Valve Maintenance (1 per yr/15 months)																
.709	.749	Vault Maintenance (≥200 cubic feet)(1 per yr/15 months)																
.603(b)	.751	Prevention of Accidental Ignition (hot work permits)																
.603(b)	.225(b)	Welding – Procedure																
.603(b)	.227/.229	Welding – Welder Qualification																
.603(b)	.243(b)(2)	NDT – NDT Personnel Qualification																
.709	.243(f)	NDT Records (Pipeline Life)																
.709		Repair: pipe (Pipeline Life); Other than pipe (5 years)																

Comments:

CORROSION CONTROL RECORDS			S	U	N/A	N/C
.491	.491(a)	Maps or Records				
.491	.459	Examination of Buried Pipe when Exposed				
.491	.465(a)	Annual Pipe-to-soil Monitoring (1 per yr/15 months)				
.491	.465(b)	Rectifier Monitoring (6 per yr/2½ months)				
.491	.465(c)	Interference Bond Monitoring – Critical (6 per yr/2½ months)				
.491	.465(c)	Interference Bond Monitoring – Non-critical (1 per yr/15 months)				
.491	.465(d)	Prompt Remedial Actions				
.491	.465(e)	Unprotected Pipeline Surveys, CP active corrosion areas (1 per 3 cal yr/39 months)				
.491	.467	Electrical Isolation (Including Casings)				
.491	.469	Test Stations – Sufficient Number				

STANDARD INSPECTION REPORT OF A GAS TRANSMISSION PIPELINE

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

CORROSION CONTROL RECORDS			S	U	N/A	N/C
.491	.471	Test Lead Maintenance				
.491	.473	Interference Currents				
.491	.475(a)	Internal Corrosion; Corrosive Gas Investigation				
.491	.475(b)	Internal Corrosion; Internal Surface Inspection; Pipe Replacement				
.491	.477	Internal Corrosion Control Coupon Monitoring (2 per yr/7½ months)				
.491	.481	Atmospheric Corrosion Control Monitoring (1 per 3 cal yr/39 months onshore; 1 per yr/15 months offshore)				
.491	.483/.485	Remedial: Replaced or Repaired Pipe; coated and protected; corrosion evaluation and actions				

Comments:

Leave this list with the operator.

Recent PHMSA Advisory Bulletins (Last 2 years)

<u>Number</u>	<u>Date</u>	<u>Subject</u>
ADB-04-02	July 22, 2004	Pipeline Safety: Semi-Annual Reporting of Performance Measures for Gas Transmission Pipeline Integrity Management
ADB-04-03	August 18, 2004	Pipeline Safety: Unauthorized Excavations and the Installation of Third-Party Data Acquisition Devices on Underground Pipeline Facilities
ADB-04-04	September 23, 2004	Potential for Damage to Pipeline Facilities Caused by the Passage of Hurricane Ivan
ADB-04-05	November 26, 2004	Pipeline Safety: Operator Qualification Requirements
ADB-05-01	January 21, 2005	Pipeline Safety: Semi-Annual Reporting of Performance Measures for Gas Transmission Pipeline Integrity Management
ADB-05-02	April 6, 2005	Pipeline Safety: Strapping Table Calibration for Pipeline Breakout Tank Operators
ADB-05-03	May 23, 2005	Pipeline Safety: Planning for Coordination of Emergency Response to Pipeline Emergencies
ADB-05-04	July 29, 2005	Integrity Management Notifications for Gas Transmission Lines
ADB-05-05	August 10, 2005	Pipeline Safety Advisory Bulletin - Inspecting and Testing Pilot-Operated Pressure Relief Valves
ADB-05-06	August 11, 2005	ADB-05-06 - Pipeline Safety - Countermeasures to Prevent Human Fatigue in the Control Room
ADB-05-07	September 7, 2005	Pipeline Safety Advisory - Potential for damage to Natural Gas Distribution Pipeline Facilities Caused by the Passage of Hurricane Katrina
ADB-05-08	September 7, 2005	Pipeline Safety Advisory - Potential for damage to Pipeline Facilities Caused by the Passage of Hurricane Katrina
ADB-06-01	January 17, 2006	Pipeline Safety: Notice to Operators of Natural Gas and Hazardous Liquid Pipelines To Integrate Operator Qualification Regulations into Excavation Activities

For more PHMSA Advisory Bulletins, go to <http://ops.dot.gov/regs/advise.htm>